

**Title \*** Finley-Guy PIK-123-3.40  
**Culvert/Bridge Number** PIK-123-3.40  
**Geo Location** 40.061191650984874 -83.4129873961857  
**General Appraisal** 5 Fair condition - all primary structural elements are sound, but may have minor section loss  
**Span Size** 52 inches  
**Culvert Length** 40ft  
**Size of Culvert** 52x31 Steel Arch  
**Type Culvert** Metal

### Conduit

**Level of Inspection** M- MANNED ENTRY INSPECTION  
**Material** 6 SATISFACTORY  
**Conduit Alignment** 8 VERY GOOD  
**Shape** 7 GOOD  
**Seams and Joints** 4 POOR  
**Slab**  
**Abutments**  
**Headwalls**  
**End Structure**

### Channel

**Channel Alignment** 8 Very Good Channel has straight alignment for more than 100 feet upstream. Flow hits protective materials placed to protect conduit material.  
**Conduit Waterway Blockage** 8 Very Good Minor amounts of sediment build-up with no appreciable loss of opening.  
**Scour**  
**Channel Projection** 8 Very Good No noteworthy deficiencies which affect the condition of the channel protection 100 feet upstream. Banks are protected or well vegetated.

### Approaches

**Pavement** 9 Excellent No noticeable defects.  
**Guardrail**  
**Embankment**  
**Comments** Rust, but not flaking rust. Joint under pavement is starting to come apart.  
**Owner** Rapp, Aaron  
**Completed DateTime** 11/20/2024 12:00:00 AM  
**Request Category** Culvert Inspection  
**Group** Ops-Drainage