

Title * Olmstead JEF-51-2.46
Culvert/Bridge Number JEF-51-2.46
Geo Location 39.919036101972644 -83.27146477997303
General Appraisal 8 Very good condition - no problems noted
Span Size 30 inches
Culvert Length 48 feet
Size of Culvert 30 inch
Type Culvert RCP

Conduit

Level of Inspection X - INPSECTED FROM ENDS OF CONDUIT (NON-ENTRY)
Material 9 EXCELLENT
Conduit Alignment 9 EXCELLENT
Shape 9 EXCELLENT
Seams and Joints 9 EXCELLENT
Slab
Abutments
Headwalls
End Structure

Channel

Channel Alignment 7 Good Silt and gravel buildup restrict half of the channel. Tree or bush growing in the channel.
Conduit Waterway Blockage 9 Excellent No blockage. Designed condition.
Scour 7 Good Minor scour holes developing at inlet or outlet. Top of footings is exposed. Probing indicates soft material in scour hole.
Channel Projection 8 Very Good No noteworthy deficiencies which affect the condition of the channel protection 100 feet upstream. Banks are protected or well vegetated.

Approaches

Pavement 7 Good Minor problems: Raveling, hairline or map cracking. No settlement.
Guardrail
Embankment 9 Excellent No noteworthy deficiencies which affect the condition of the embankment up to 50 feet away from the conduit.
Comments Need to realign waterway at inlet and add rip rap. Starting to erode due water not being directed into culvert.
Owner Rapp, Aaron
Completed DateTime 12/24/2024 12:00:00 AM
Request Category Culvert Inspection
Group Ops-Drainage