

Title * Rosedale-Plain City DAR-24-5.56
Culvert/Bridge Number DAR-24-5.56
Geo Location 40.087796098830076 -83.35655173072668
General Appraisal 9 As built condition
Span Size 8ft
Culvert Length 40ft
Size of Culvert 8x5 box
Type Culvert Concrete

Conduit

Level of Inspection M- MANNED ENTRY INSPECTION
Material 9 EXCELLENT
Conduit Alignment 9 EXCELLENT
Shape 9 EXCELLENT
Seams and Joints 8 VERY GOOD
Slab
Abutments
Headwalls
End Structure

Channel

Channel Alignment 9 Excellent Channel is flowing through conduit. No negative effects to channel protection of conduit.
Conduit Waterway Blockage 9 Excellent No blockage. Designed condition.
Scour 9 Excellent No evidence of scour at either inlet or outlet of conduit.
Channel Projection 9 Excellent Embankment protection not required or in stable condition.

Approaches

Pavement 8 Very Good Hairline cracks in pavement. Minor scaling.
Guardrail
Embankment 9 Excellent No noteworthy deficiencies which affect the condition of the embankment up to 50 feet away from the conduit.
Comments
Owner Rapp, Aaron
Completed DateTime 12/04/2024 12:00:00 AM
Request Category Culvert Inspection
Group Ops-Drainage