

Title * Rosedale-Plain City DAR-24-7.30
Culvert/Bridge Number DAR-24-7.30
Geo Location 40.09304160288107 -83.3294977247715
General Appraisal 9 As built condition
Span Size 6 ft
Culvert Length 32ft
Size of Culvert 6x4 box
Type Culvert Concrete

Conduit

Level of Inspection M- MANNED ENTRY INSPECTION
Material 9 EXCELLENT
Conduit Alignment 9 EXCELLENT
Shape 9 EXCELLENT
Seams and Joints 8 VERY GOOD
Slab
Abutments
Headwalls
End Structure

Channel

Channel Alignment 7 Good Silt and gravel buildup restrict half of the channel. Tree or bush growing in the channel.
Conduit Waterway Blockage 9 Excellent No blockage. Designed condition.
Scour 8 Very Good Minor scour holes developing at inlet or outlet. Scour protection placed.
Channel Projection 9 Excellent Embankment protection not required or in stable condition.

Approaches

Pavement 8 Very Good Hairline cracks in pavement. Minor scaling.
Guardrail 8 Very Good No noteworthy deficiencies that affect the condition of the guardrail within 50 feet of the conduit.
Embankment 9 Excellent No noteworthy deficiencies which affect the condition of the embankment up to 50 feet away from the conduit.

Comments

Owner Rapp, Aaron
Completed DateTime 12/03/2024 12:00:00 AM
Request Category Culvert Inspection
Group Ops-Drainage