

Title * Warner DAR-134-0.24

Culvert/Bridge Number DAR-134-0.24

Geo Location 40.10738587199893 -83.23532402515411

General Appraisal 6 Satisfactory condition - structural elements show some deterioration

Span Size 60inch

Culvert Length 40ft

Size of Culvert 41x60 Steel Arch

Type Culvert Metal

Conduit

Level of Inspection M- MANNED ENTRY INSPECTION

Material 6 SATISFACTORY

Conduit Alignment 8 VERY GOOD

Shape 8 VERY GOOD

Seams and Joints 8 VERY GOOD

Slab

Abutments

Headwalls

End Structure

Channel

Channel Alignment 8 Very Good Channel has straight alignment for more than 100 feet upstream. Flow hits protective materials placed to protect conduit material.

Conduit Waterway Blockage 9 Excellent No blockage. Designed condition.

Scour 8 Very Good Minor scour holes developing at inlet or outlet. Scour protection placed.

Channel Projection 7 Good Channel bank(s) beginning to slump. Embankment protection has minor damage. Bank protection needs minor repairs.

Approaches

Pavement 7 Good Minor problems: Raveling, hairline or map cracking. No settlement.

Guardrail

Embankment 7 Good Moderate rutting from drainage; minor amount of bare soil exposed.

Comments Layers of flaking rust throughout invert

Owner Rapp, Aaron

Completed DateTime 12/06/2024 12:00:00 AM

Request Category Culvert Inspection

Group Ops-Drainage