

Title * West Jefferson-Kiousville FAI-22-3.97
Culvert/Bridge Number FAI-22-3.97
Geo Location 39.85726158688638 -83.28630544245243
General Appraisal 4 Poor condition - advanced section loss, deterioration, or spalling
Span Size 36 inch
Culvert Length 40 feet
Size of Culvert 36 inch
Type Culvert Metal

Conduit

Level of Inspection X - INPSECTED FROM ENDS OF CONDUIT (NON-ENTRY)
Material 4 POOR
Conduit Alignment 7 GOOD
Shape 6 SATISFACTORY
Seams and Joints 6 SATISFACTORY
Slab
Abutments
Headwalls
End Structure

Channel

Channel Alignment 7 Good Silt and gravel buildup restrict half of the channel. Tree or bush growing in the channel.
Conduit Waterway Blockage 4 Poor Conduit waterway blockage is less than 40% of the cross-sectional area of the opening. Occasional overtopping of roadway. Large deposits of debris are in the waterway.
Scour 6 Satisfactory Minor scour holes, 1 foot or less deep, developing at inlet or outlet. Footings along the side are exposed less than 6 inches.
Channel Projection 7 Good Channel bank(s) beginning to slump. Embankment protection has minor damage. Bank protection needs minor repairs.

Approaches

Pavement 6 Satisfactory Minor pavement deterioration: Minor potholes and cracking. Minor settlement.
Guardrail
Embankment 7 Good Moderate rutting from drainage; minor amount of bare soil exposed.
Comments Cannot see invert, but an see depression starting in berm, indicating possible loss of backfill
Owner Rapp, Aaron
Completed DateTime 01/02/2025 12:00:00 AM
Request Category Culvert Inspection
Group Ops-Drainage